



Interior walls 2x4
Notify Architect of construction
Corrected discrepancies
Verify walls and hold-downs
Revised approved in CUP file number 2005CUP0004

Area feet: 5,907 sq ft
Total area: 19,671 sq ft

Area smoke and CO2 detectors are required in both sleeping areas installed per the manufacturers requirements.

Womens sleeping area

Mens sleeping area

Restrooms

Smoke/Carbon Monoxide Detectors, battery operated First Alert SA3120 mounted 12" from the ceiling