



WATER SAMPLING STATION INTERNAL VIEW

NOTES:

1. WATER SAMPLING STATION MUST BE KORALEEN.
2. COMPRESSION FITTING (OR APPROVED EQUIVALENT WITH CITY ENGINEER'S APPROVAL). USE STAINLESS STIFFENER WITH POLYPIPE. BAND CLAMPS AND BARBED FITTINGS NOT ALLOWED. ALL BRASS COMPONENTS SHALL CONFORM TO THE LATEST VERSIONS OF NSF 61 AND ANSI/AWWA STANDARD C800 AND SHALL BE STAMPED/ EMBOSSED TO SHOW THE PRODUCT IS MADE FROM NO LEAD ALLOY.
3. COPPER TUBING TYPE K (SOFT), 4 INCHES OF SAND BEDDING AROUND PIPE, CONTINUOUS UNBROKEN LENGTH FROM MAIN TO METER SETTER WITH 1 FOOT OF SLACK LOOP.
4. NO SPLICES ALLOWED IN SERVICE LINE OR CASING.
5. TRACE WIRES MUST BE VISIBLE IN METER BOX.
6. METER BOX SHALL BE PERPENDICULAR TO SIDEWALK, PROPERTY LINE OR AS DIRECTED. TOP OF BOX SHALL BE FLUSH WITH FINISH GRADE.



WATER SAMPLING STATION

U-WAT-17-Water Sampling Station - 04082024.dwg

| | |
|----------------|----------|
| DRAWING NUMBER | U-WAT-17 |
| SCALE | NTS |
| REVISION DATE | 4/24 |
| DEPARTMENT | PW |