

Spec or Std #	Edit Date	Action
TESC Notes	1/18/2024	Temporary Erosion and Sedimentation Control Notes: Item 11 should say 2 days between October 1 and April 30th or 7 days between May 1st and September 30th
U-SEW-1, U-STO-7	3/25/2024	Used East Jordan's CAD files to update both drawings. Added EJ model numbers. Added "locking lids".
U-WAT-17	4/8/2024	Created new spec based off of Koraleen Water Sampling Station
ST-CG-3	5/23/2024	Renamed, removed anchors, reference dimensions with WSDOT standards.
U-STO-10	5/23/2024	Modified standard to be the complete Hood, Frame and Grate rather than Hood only. Renamed appropriately.